RESOLUTION 204-13

RESOLUTION
APPROVING EMERGENCY CONTRACT FOR
THE REPAIR OF WELL 36 PUMP
IN THE BOROUGH OF CLAYTON

WHEREAS, Paul Pheasant, Director of the Clayton Public Works Department has submitted Certification of Request for Emergency purchase; and

WHEREAS, it has been determined that said purchase and repair is an emergency condition; and

WHEREAS, Paul Pheasant, Director of Public Works, has issued said request (attached hereto) indicating the reasons said emergency exists; and

WHEREAS, Paul Pheasant, Director of Public Works, had obtained a quote from AC Schultes, Inc. to repair said emergency dated November 8, 2013; and

WHEREAS, the governing body is in agreement that said emergency contract must be awarded without public bidding pursuant to N.J.S.A. 40A:11-6.

NOW, THEREFORE, BE IT RESOLVED by the Mayor and Council of the Borough of Clayton, County of Gloucester, and State of New Jersey as follows:

1. That the governing body does hereby authorize the execution of a Contract between the Borough of Clayton and AC Schultes, Inc. for the repair of said Well #6 Pump per the estimate of $11,703.00.

ADOPTED at a meeting of the Mayor and Council of the Borough of Clayton, in the County of Gloucester, State of New Jersey, held on November 14, 2013.

BOROUGH OF CLAYTON

THOMAS BIANCO, Mayor

Attest:

CHRISTINE NEWCOMB
Borough Clerk

CERTIFICATION

I, Christine Newcomb, Clerk of the Borough of Clayton, do hereby certify that the foregoing Resolution was presented and duly adopted by the Borough Council at a regular meeting of the Borough of Clayton Council, held on November 14, 2013.

CHRISTINE NEWCOMB, Borough Clerk

A.C. Schultes, Inc.
664 S. Evergreen Avenue
Woodbury Heights, NJ 08097
24 Hour Service
(856) 845-5656
Fax (856) 845-1335
gusiv@acschultes.com

November 8, 2013

Borough of Clayton
125 N. Delsea Drive
Clayton, NJ 08312

Attention:	Joe Hunt
Email:	jhunt@claytonnj.com
Phone:	856-881-3778
Fax:	856-881-9261

Reference:	Well #6: Emergency Repairs ACS Job #P28010-13

Dear Sir:

On November 8, 2013, A.C. Schultes, Inc. mobilized to the above referenced jobsite to remove the pumping equipment, repair, and reinstall. After removal, it was found that the line shaft had broken in the bottom 10' section of the column assembly. From the failure that occurred, the column assembly and pump assembly were both damaged. The following labor and materials are necessary to return the unit to operation:

- Furnish new stainless steel headshaft.
- Furnish 40' of new 6" x 1" column assembly with stainless steel line shafting and bronze drop-in bearing brackets.
- Furnish new Flowserve 10 ELM 2-stage bowl assembly.
- Furnish new 6" x 10' suction pipe.
- Provide installation and startup services.

Total project cost: $11,703.00

If you have any additional questions regarding this project, please feel free to contact this office.

Sincerely,

A.C. SCHULTES, INC.

Alex Rodack

Alex Rodack
Project Manager
AR/sjs/J: JOBS P/ P28010-13/110813